SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Maine Dept. of Health & Human Services
Division of Environmental Health, 11 SHS
(207) 287-5672 FAX (207) 287-4172

PROPERTY LOCATION

City, Town, or Plantation	LAMOINE
Street or Road	SEAL POINT ROAD
Subdivision, Lot #	

OWNER/APPLICANT INFORMATION

Name (last, first, MI): COLLIER, JAMES — ☒ Owner ☐ Applicant

Mailing Address of ☒ Owner ☐ Applicant: 62 HANCOCK ST. APT # 2, ELLSWORTH, ME. 04605

Daytime Tel. #: (207) 266 - 5581

>> CAUTION: LPI APPROVAL REQUIRED <<

Town/City LAMOINE Permit # 1854

Date Permit Issued 8/19/17 Fee $ 250.00 Double Fee Charged ( )

Local Plumbing Inspector Signature L.P.I. # 1040

DEP FEE $15.00 ☐ Owner ☐ Town ☒ State

The Subsurface Wastewater Disposal System shall not be installed until a Permit is issued by the Local Plumbing Inspector. The Permit shall authorize the owner or installer to install the disposal system in accordance with the application and the Maine Subsurface Wastewater Disposal Rules.

Municipal Tax Map # 12 Lot # 5

OWNER OR APPLICANT STATEMENT

I state and acknowledge that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Department and/or Local Plumbing Inspector to deny a permit.

Signature of Owner or Applicant — Date

CAUTION: INSPECTION REQUIRED

I have inspected the installation authorized above and found it to be in compliance with Subsurface Wastewater Disposal Rules Application. (1st Date Approved)

Local Plumbing Inspector Signature — (2nd Date Approved)

PERMIT INFORMATION

TYPE OF APPLICATION

☒ 1. First Time System
☐ 2. Replacement System
Type Replaced: _____
Year Installed: _____
☐ 3. Expanded System
☐ a. Minor Expansion
☐ b. Major Expansion
☐ 4. Experimental System
☐ 5. Seasonal Conversion

SIZE OF PROPERTY

5½ ☐ sq. ft. ☒ acres

SHORELAND ZONING

☐ Yes ☒ No

THIS APPLICATION REQUIRES

☒ 1. No Rule Variance
☐ 2. First Time System Variance
☐ a. Local Plumbing Inspector Approval
☐ b. State & Local Plumbing Inspector Approval
☐ 3. Replacement System Variance
☐ a. Local Plumbing Inspector Approval
☐ b. State & Local Plumbing Inspector Approval
☐ 4. Minimum Lot Size Variance
☐ 5. Seasonal Conversion Permit

DISPOSAL SYSTEM TO SERVE

☒ 1. Single Family Dwelling Unit, No. of Bedrooms: 3
☐ 2. Multiple Family Dwelling, No. of Units: _____
☒ 3. Other: (SPECIFY) 1 BEDROOM EFFICIENCY APARTMENT CONNECTED TO HOUSE

Current Use: ☐ Seasonal ☐ Year Round ☒ Undeveloped

DISPOSAL SYSTEM COMPONENT(S)

☒ 1. Complete Non-engineered System
☐ 2. Primitive System (graywater & alt. toilet)
☐ 3. Alternative Toilet, specify: _____
☐ 4. Non-engineered Treatment Tank (only)
☐ 5. Holding Tank, _____ gallons
☐ 6. Non-engineered Disposal Field (only)
☐ 7. Separated Laundry System
☐ 8. Complete Engineered System(2000 gpd or more)
☐ 9. Engineered Treatment Tank (only)
☐ 10. Engineered Disposal Field (only)
☐ 11. Pre-treatment, specify: _____
☐ 12. Miscellaneous components

TYPE OF WATER SUPPLY

TO BE
☒ 1. Drilled Well ☐ 2. Dug Well ☐ 3. Private
☐ 4. Public ☐ 5. Other: _____

DESIGN DETAILS (SYSTEM LAYOUT SHOWN ON PAGE 3)

TREATMENT TANK

☒ 1. Concrete TWO 1000 GAL. TANKS IN-SERIES
OR ☒ a. Regular ☒ b. Low Profile
☐ 2. Plastic
☐ 3. Other: _____
CAPACITY 2000 gallons

SOIL DATA & DESIGN CLASS

PROFILE CONDITION
3 / C/A, III
at Observation Hole # 1
Depth 22 "
OF MOST LIMITING SOIL FACTOR

DISPOSAL FIELD TYPE & SIZE

☐ 1. Stone Bed ☐ 2. Stone Trench
☒ 3. Proprietary Device 32 TYPE B43 GSE UNITS
☒ a. Cluster Array ☐ c. Linear
☒ b. Regular load ☐ d. H-20 load
☐ 4. Other: _____
SIZE 1536 ☒ sq. ft. ☐ lin. ft.

DISPOSAL FIELD SIZING

☐ 1. Medium -- 2.6 sq. ft./gpd
☒ 2. Medium-Large -- 3.3 sq. ft./gpd
☐ 3. Large -- 4.1 sq. ft./gpd
☐ 4. Extra Large -- 5.0 sq. ft./gpd

GARBAGE DISPOSAL UNIT

☒ 1. No ☐ 2. Yes ☐ 3. Maybe
If Yes or Maybe, specify one below:
☐ a. Multi-compartment Tank
☐ b. _____ Tanks in Series
☐ c. Increase in Tank Capacity
☐ d. Filter on Tank Outlet

EFFLUENT/EJECTOR PUMP

☒ 1. Not Required
☐ 2. May be Required
☐ 3. Required
Specify only for engineered systems
DOSE: _____ gallons

DESIGN FLOW

390 gallons per day
BASED ON
☒ 1. Table 4A (dwelling unit(s)
☐ 2. Table 4C (other facilities)
SHOW CALCULATIONS for other facilities
3 BEDROOM HOUSE 270 GPD
1 BEDROOM APARTMENT 120 GPD
390 GPD
☐ 3. Section 4G (meter readings)
ATTACH WATER METER DATA

LATITUDE AND LONGITUDE

at Center of Disposal Area
Lat. 44° d 29' m 05" s N
Lon. 68° d 16' m 00" s W
If g.p.s., state margin of error 30'±

SITE EVALUATOR STATEMENT

I certify that on 10/11/16 (date) I completed a site evaluation on this property and state that the data reported are accurate and that the proposed system is in compliance with the State of Maine Subsurface Wastewater Disposal Rules (10-144A CMR 241).

Site Evaluator Signature — SE# 319 — Date 10-18-16

WILLIAM A. LaBELLE, JR. — Site Evaluator Name Printed
(207) 537 - 5900 — Telephone Number
labelleseptic@rivah.net — E-mail Address

Note: Changes to or deviations from the design should be confirmed with the Site Evaluator.

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Maine Dept. of Health & Human Services
Division of Environmental Health, 11 SHS
(207) 287-5672 FAX (207) 287-4172

Town, City, Plantation	Street, Road, Subdivision	Owner or Applicant Name
LAMOINE	SEAL POINT ROAD	JAMES COLLIER

SUBSURFACE WASTEWATER DISPOSAL PLAN

SCALE: 1" = 20 FT.



FILL REQUIREMENTS		CONSTRUCTION ELEVATIONS	SYSTEM:	PRIVY:	ELEVATION REFERENCE POINT
Depth of Backfill (Upslope)	22"	Finished Grade Elevation	MIN. -41"		Location & Description NAIL @2' ABOVE GROUND IN 10" DIA. SPLIT APPLE TREE.
Depth of Backfill (Downslope)	28"-30"	Top of Distribution Pipe	-49"		
Depths @ cross-section shown below or on X-sec. detail.		Bottom of Disposal Field (GSF UNITS)	-60"		Reference Elevation is: 0"

DISPOSAL AREA CROSS SECTION (SEE ATTACHED CROSS SECTION)

NOTES:

1. Tank(s) must be 8' minimum from building.
2. Grade surrounding area to divert surface water away from system.
3. Well to be 51' minimum from septic tank(s) and 100' minimum from disposal field.
4. All work done adjacent to wetlands and water bodies must be done in compliance with section 12 of the Subsurface Wastewater Disposal Rules. Erosion and sediment control measures must be in accordance with the March 2003 edition of the Maine DEP Handbook "Maine Erosion and Sediment Control BMPS" (DEPW0588).
5. Install septic tank(s) risers 18" in diameter "minimum" to within 6" of finished grade on inlet, cleanout and outlet covers (recommend extending risers to finish grade).
6. Full basement below grade foundation, frost wall or columns must be 20' minimum from stone around chambers and slab on grade must be 15' minimum from stone around chambers.

Site Evaluator's Signature	S.E. #	Date
[signature]	319	10-18-16

Town, City, Plantation	Street, Road, Subdivision	Owner or Applicant Name
LAMOINE	SEAL POINT ROAD	JAMES COLLIER

SITE PLAN:

SCALE: 1" = 50 FT.



W. C. Ly — Site Evaluator's Signature

319 — S.E. #

10-18-16 — Date

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Maine Dept. of Health & Human Services
Division of Environmental Health, 11 SHS
(207) 287-5672 FAX (207) 287-4172

Town, City, Plantation	Street, Road, Subdivision	Owner or Applicant Name
LAMOINE	SEAL POINT ROAD	JAMES COLLIER

SITE PLAN — Scale 1" = 50 Ft.

SITE LOCATION PLAN
(Attach map from Maine Atlas for First Time System Variance)



(SEE ATTACHED SITE PLAN)

SOIL PROFILE DESCRIPTION AND CLASSIFICATION (Location of Observation Holes Shown Above or on pg. 2A)

Observation Hole #1 ☒ Test Pit ☐ Boring

1/2 " Depth of organic horizon above mineral soil

Texture	Consistency	Color	Mottling
SANDY SHALY LOAM	FRIABLE	DARK BROWN (10YR 3/3)	N.E.
		DARK YELLOWISH BROWN (10YR 4/6)	
LEDGE			

DEPTH BELOW MINERAL SOIL SURFACE (inches): 10, 20, 30, 40, 50

Soil Profile	Classification Condition	Slope	Limiting Factor	
3	C/A, III	3-4 %	22 " Depth	☐ Ground Water ☐ Restrictive Layer ☒ Bedrock ☐ Pit Depth

Observation Hole #2 ☒ Test Pit ☐ Boring

1/2 " Depth of organic horizon above mineral soil

Texture	Consistency	Color	Mottling
SANDY SHALY LOAM	FRIABLE	DARK BROWN (10YR 3/3)	N.E.
		DARK YELLOWISH BROWN (10YR 4/6)	
POSSIBLE LEDGE			

DEPTH BELOW MINERAL SOIL SURFACE (inches): 10, 20, 30, 40, 50

Soil Profile	Classification Condition	Slope	Limiting Factor	
3	C/A, III	3-4%	24" Depth	☐ Ground Water ☐ Restrictive Layer ☒ Bedrock ☐ Pit Depth

WAC 2/8
Site Evaluator's Signature

319
S. E. #

10-18-16
Date

GSF UNITS CROSS SECTION

SCALE: 1" = 5'



Ⓐ

NOTE: GRADE UPSLOPE AND DOWNSLOPE TO DIVERT SURFACE WATER AWAY FROM SYSTEM.

TOP 4" OF FILL TO BE A GOOD LOAM SOIL MIX TO ESTABLISH A GOOD VEGETATIVE COVER; SEED AND AND MULCH TO PREVENT EROSION, SEC.11-G.

FILL MATERIAL SHALL BE 8"-12" THICK OVER GSF UNITS AND SHALL BE GRAVELLY COARSE SAND TO THE STANDARDS IN SEC. 11-E IN THE SUBSURFACE RULES.



ELEVATIONS:

ELEV. REF. PT. (ERP):	0"
FINISHED GRADE:	-41" MIN.
TOP OF PIPE:	-49"
TOP OF GSF UNITS:	-53"
BOTTOM OF GSF UNITS:	-60" *
BOTTOM OF SAND:	-66"

NOTE:
SYSTEM MUST BE INSTALLED ACCORDING TO THE RULES AND PRACTICES SET FORTH IN THE MOST CURRENT VERSION OF THE STATE OF MAINE SUBSURFACE WASTEWATER DISPOSAL RULES. INSTALLATION CONTRATOR MUST BE FAMILIAR WITH SAID RULES AND CONSTRUCT SYSTEM IN FULL COMPLIANCE WITH SECTION 11 OF SAID RULES.

OWNER: JAMES COLLIER

LOCATION: LAMOINE

William A. LaBelle, Jr. — WILLIAM A. LaBELLE, JR.

319 — S.E.#

10-18-16 — DATE